

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

S.CHETAN SINGH SARVHITKARI SR.SEC.VIDYA MANDIR
S.CHETAN SINGH SARVHITKARI SR.SEC.VIDYA MANDIR, JAGDAMBAY ROAD,MANSA

No.: DWTL/MNS/2324/00009 Dated : 25/04/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SUM/20/23-23 Dated: 12/04/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 24/04/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa



D/A : Test Report

Authorized Signatory
For, District Water Testing Laboratory, Mansa

DISTRICT WATER TESTING LABORATORY, MANSA
Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmanasa@gmail.com

TEST REPORT

Name & Address of Customer : S.CHETAN SINGH SARVHITKARI SR.SEC.VIDYA MANDIR S.CHETAN SINGH SARVHITKARI SR.SEC.VIDYA MANDIR, JAGDAMBAY ROAD,MANSA	Customer Reference No.	No : SUM/20/23-23 Dated : 12/04/2023
	Sample Submitted by	Sh. Mohinderpaul Singla
	Date of Sample Receipt	24/04/2023
	Analysis Starting Date	24/04/2023
	Analysis completion Date	25/04/2023

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC000123000000064F	Sample Type :	Water
Test Report No.:	DWTL/MNS/2324/00009	Date of Issue :	25/04/2023
Registration no.:	DWTL/MNS/REG2324/00010	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	S.CHETAN SINGH SARVHITKARI SR.SEC.VIDYA MANDIR, JAGDAMBAY ROAD,MANSA / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Mansa
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Colour	3	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
2	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
3	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
4	TDS	90	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Alkalinity	52	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
6	Hardness	52	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
7	Calcium	13	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
8	Magnesium	5	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
9	Chloride	14	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory, Mansa

----- End of the Test Report -----